


Mark Shelton, District Engineer

**ADDENDUM 001
REQUEST FOR BID Metal Building
B10-11327-TB**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including it** with the original bid. The due date for receipt of proposals is changed to: **TUESDAY, NOVEMBER 23, 2010 at 1:00 PM** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.



Item 1:	Brown Roof Panels (Galvalume was typed incorrectly)
Item 2:	Include all necessary anchor bolts
Item 3:	No gutters on Eave Trim
Item 4:	Include Gable (Rake) Trim on 30' Peak
Item 5:	There is a possibility of ordering up to six units.
Item 6:	The 2 side walls will be completely closed in.
Item 7:	The End walls will be closed from 20' Header to 30' Peak.
Item 8:	Price quoted should be good Notice To Proceed through May 31, 2011.
Item 9:	Delivery Time on Each Building Ordered is: ARO / 30 to 45 days.
Item 10:	Include Pricing for 90 Degree Base Angle and Base Trim.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name Tammy Baker Title Procurement Agent
Contractor/ Signature _____	Department of Transportation <i>Tammy L Baker</i>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: <i>(Insert date signed)</i>