



Mark Shelton, District Engineer

**Southeast District**  
2675 North Main Street  
P.O. Box 160  
Sikeston, MO 63801  
(573) 472-5318  
Fax (573) 472-5890  
Toll free 1-888 ASK MoDOT

**ADDENDUM 002  
REQUEST FOR QUOTE  
Network Connections  
(Q10-11346-TB)**

Bidders should acknowledge receipt of Addendum 002 (TWO) by **signing** and **including it** with the original quote. The due date for receipt of proposals is extended by this Addendum to: **Thursday, FEBRUARY 3, 2011 at 1:00 p.m., C.S.T.** Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Question 1 - Regarding Type, Color and Placement of Conduit for the project  
The contractor shall be allowed to use either 2" PVC or HDPE conduit for this project.  
The conduit color shall be gray or orange for this project.  
The conduit shall be placed at a minimum depth of 18" below the surface grade.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Tammy Baker Procurement Agent
Contractor Signature  <hr/> (Signature of person authorized to sign)	Department of Transportation  <div style="text-align: center;"><i>Tammy Baker</i></div> <hr/> (Authorizing Signature)
Date Signed:	Date Signed: 1/27/2011