



Paula Gough, P.E., District Engineer

Northeast District
P.O. Box 1067
South Route 61
Hannibal, MO 63401
(573) 248-2490
fax (573) 248-2497
Toll free 1-888 ASK MoDOT
www.modot.org

**Addendum 001
Request for Quote
Q03-10-0036 Interlocking Blocks**

Bidders shall acknowledge receipt of Addendum 001 by signing and including it with the original quote. The due date for receipt of quote remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Current description:

2 - Interlocking blocks measuring at least 50 lineal feet, minimum 2' wide with total height to be 6'. Blocks to be offset if stacked. Blocks to be approximately 1900 lbs. each. Blocks to have no cold joints.

Corrected description:

2 - Interlocking concrete blocks to provide for a free standing wall measuring 50 lineal feet, 6 feet tall and approximately 2 feet wide. Blocks must be able to be stacked and arranged with alternating joints similar to a standard brick wall. Blocks with severe segregation, voids, or cold joints will be rejected and must be replaced with acceptable blocks.

Please also provide alternate bids as follows:

With Delivery \$ _____

Without Delivery \$ _____

Name and Title of Signer (Print or type)	Name and Title of Department Authority Tanya Dauma Senior Procurement Agent
Bidder/Offeror Signature	Department of Transportation – D3 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 03/16/10