



IMPORTANT BID CHANGES

August 24, 2009

RE: Addendum 01 to Bid D5-10-021Q, Fuel Tanks

Dear Bidders:

Please note that this addendum letter is to inform all potential bidders of the following changes to bid D5-10-021Q.

Item 1)

Specification currently reads:

- Each tank will be fitted with two (2) 8 inch Morrison Type emergency vents, (one primary and one interstitial), rated at 16 oz/sq in, one (1) 2-inch atmospheric updraft vent (#354 2) for Diesel tanks, and one (1) 2-inch Pressure Vacuum vent, rated at 3 in. W.C. pressure and 8 in. W.C. vacuum, with 2-inch N.P.T. body connection for unleaded tanks.

Specification amended to read:

- Each tank will be fitted with two (2) 8 inch Morrison Type or equivalent emergency vents, (one primary and one interstitial), rated at 16 oz/sq in, one (1) 2-inch atmospheric updraft vent (#354 2) for Diesel tanks, and one (1) 2-inch Pressure Vacuum vent for Unleaded, rated at 3 in. W.C. pressure and 8 in. W.C. vacuum, with 2-inch N.P.T. body connection for unleaded tanks. All 2-inch atmospheric updraft and Pressure Vacuum vents shall be supplied with stem pipes to reach heights required by code.

Item 2)

Clarification: All components shall be shipped uninstalled to avoid damage while in transit.

Bid opening will be changed to open on August 27, 2009 at 1:00 PM CDST.

Addendum must be signed and returned with bid.

If you have any questions, please call.

By signing, _____, I fully understand the addendum request.
Vendor

Date _____

Thank you!

Corey Duemmel, D5 General Services
(573) 526-6956