

**ADDENDUM 002
REQUEST FOR BIDS
RFQ NUMBER: D9091129R9**

Bidders shall acknowledge receipt of Addendum 002 (two) by signing and including it with the original quote. If original quote has been submitted sign and fax back to 417-469-3449. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Carmella Green Int. GS Specialist
Contractor/Offeror Signature <hr/>	Department of Transportation <i>Carmella Green</i> <hr/>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 01/06/09

Question: Under "Two Flasher Units" Item 2, are there 2 - 12" LED lights on one pole (per power system) (1 LED light facing each direction?) or are there 2 poles each with 1 - 12" LED, 1 pole at each end of the flood zone?

Answer: Bid item 2 states that there are to be two 12" amber LED lights. This is because there are two poles, one pole with one light to be placed at the right side of each lane in the right of way facing traffic to alert motorist of the flooded crossing.