



Kevin Keith, Director

**ADDENDUM 001
REQUEST FOR BIDS
(Marble Hill Sewer)
Request for Bid 9-120928TV**

Bidders should acknowledge receipt of Addendum 001 (ONE) by **signing** and **including** it with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Tom Veasman Sr. General Services Specialist
Contractor/Offeror Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: Sept. 24, 2012

- The tap fees to be paid to the City of Marble Hill will be paid by MoDOT.
- Installation of casing across Opossum Creek will be by directional boring method only to minimize siltation and erosion. Any disturbed areas shall require cleanup, grading and seeding of disturbed area with no exposed area being unprotected for more than seven days. The casing to be used shall be HDPE SDR-11 and 4" in diameter, helping to ensure a seamless watertight conduit to house 1 1/4" force main.
- Sub-section A of Specification 01039, Section 1.3 - Field Engineering shall be deleted from the RFB as follows:
 - A. Employ a Land Surveyor registered in the State of Missouri and acceptable to Architect/Engineer/Designer.

A land surveyor will not be required. The contractor will coordinate the staking/surveying of this project with MoDOT.