



SECTION 211

SUBGRADE SCARIFYING

211.1 Description. This work shall consist of loosening the surface of the roadbed and removing all rocks larger than 4 inches (100 mm). Tentative locations of subgrade scarifying will be shown on the plans, but the engineer will specify all locations of this work by written order.

211.2 Construction Requirements. The engineer will specify areas where subgrade scarifying is to be performed. The contractor shall perform all specified work necessary to loosen the surface of the roadbed over the full width to a depth of 6 inches (150 mm) below the finished grading section, and to remove all rocks larger than 4 inches (100 mm). Oversized material shall be disposed of as directed by the engineer. After all oversized material has been removed; the roadbed shall be brought back to a satisfactory grade and cross section by the addition of extra material, if needed, without rocks exceeding 4 inches (100 mm).

211.3 Method of Measurement. Measurement will be along the centerline of the roadbed, regardless of the width, to the nearest 1/10 station (5 m) for each segment and totaled to the nearest 100 feet (25 m) for the sum of all segments.

211.4 Basis of Payment. The accepted quantity of subgrade scarifying will be paid for at the contract unit price.